



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2017010203999974

NAME AND ADDRESS OF THE APPLICANT

SCAME PARRE S.P.A.
Via Costa Erta,15-24020 PARRE (Bg)ITALY

NAME AND ADDRESS OF THE MANUFACTURER

SCAME PARRE S.P.A.
Via Costa Erta,15-24020 PARRE (Bg)ITALY

NAME AND ADDRESS OF THE FACTORY

SCAME-SK S.R.O. (V030829)
Nabrezie Oravy 628/3 02601 Dolny Kubin Slovakia

PRODUCT NAME, MODEL AND SPECIFICATION

Surface-type Socket-outlet for Industrial Purposes
See Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T11918.1-2014;GB/T11918.2-2014

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462298-2018 .

Valid from: Jul.15,2018

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

President: _____

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0117708



产品认证证书

证书编号：CQC2017010203999974

申请人名称及地址

SCAME PARRE S. P. A.
Via Costa Erta, 15-24020 PARRE (Bg) ITALY

制造商名称及地址

SCAME PARRE S. P. A.
Via Costa Erta, 15-24020 PARRE (Bg) ITALY

生产企业名称及地址

SCAME-SK S. R. O. (V030829)
Nabrezie Oravy 628/3 02601 Dolny Kubin Slovakia

产品名称和系列、规格、型号

工业用明装插座
见附件

产品标准和技术要求

GB/T11918.1-2014; GB/T11918.2-2014

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462298-2018 认证规则的要求，特发此证。

发证日期：2018年07月15日

本证书的有效性依据发证机构的定期监督获得保持。

主任：_____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0117708



产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC2017010203999974

纸 号: 117708

产品名称: 工业用明装插座

型 号: 518.3257T 32A-6h/415V~ 3P+N+PE IP66/IP67

518.3253T 32A-6h/250V~ 2P+PE IP66/IP67

518.3256T 32A-6h/415V~ 3P+PE IP66/IP67

513.3253 32A-6h/250V~ 2P+PE IP44

513.3256 32A-6h/415V~ 3P+PE IP44

513.3257 32A-6h/415V~ 3P+N+PE IP44

513.3253T 32A-6h/250V~ 2P+PE IP44

513.3256T 32A-6h/415V~ 3P+PE IP44

513.3257T 32A-6h/415V~ 3P+N+PE IP44

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>