

Certificate of Compliance

Certificate Number **20080403-E238170D**
Report Reference **E238170, 1999 December 9**
Issue Date **2008 April 3**

Page 1 of 3



Issued to: **SCAME PARRE S.P.A**
VIA COSTA ERTA 15
24020 PARRE BG ITALY


This is to certify that representative samples of **ATTACHMENT PLUGS, PIN AND SLEEVE TYPE**
See Addendum for Models.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: IEC 60309-1 - Standard for Plugs, Socket-Outlets and Couplers for Industrial Purposes, Series I & II
IEC 60309-2 - Standard for Dimensional Interchangeability Requirements for Pin and Contact-Tube Accessories

Additional Information: See Addendum for Ratings.

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:
THOMAS SCIOTTO, Engineering Group Leader
Underwriters Laboratories Inc.

Reviewed by:
JON SCHUETTE, Manager CAS III
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number **20080403-E238170D**
Report Reference **E238170, 1999 December 9**
Issue Date **2008 April 3**

Page 2 of 3



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models:

Attachment Plugs, Pin and Sleeve Type Cat. Nos. SCM3100P4W, SCM3100P6W, SCM3100P7W, SCM3100P3W, SCM4100P12W, SCM4100P9W, SCM4100P7W, SCM4100P5W, SCM5100P9W, SCM5100P7W, SCM5100P5W, SCM3125P6W, SCM4125P6W, SCM5125P6W with or without defined suffixes.

Cord Connectors, Pin and Sleeve Type, Cat. Nos. SCM3100C4W, SCM3100C6W, SCM3100C7W, SCM3100C3W, SCM4100C12W, SCM4100C9W, SCM4100C7W, SCM4100C5W, SCM5100C9W, SCM5100C7W, SCM5100C5W, SCM3125C6W, SCM4125C6W, SCM5125C6W with or without defined suffixes.

Ratings:

Series I

Attachment Plug

Cat. No.	Type	Rating
SCM3125P6W	2 P, 3 W	125 A, 200-250 V ac
SCM4125P6W	3 P, 4 W	125 A, 380-415 V ac
SCM5125P6W	4 P, 5 W	125 A, 200/346 V ac 125 A, 240/415 V ac

Series II

Attachment Plug

Cat. No.	Type	Rating
SCM3100P4W	2 P, 3 W	100 A, 125 V ac
SCM3100P6W	2 P, 3 W	100 A, 250 V ac
SCM3100P7W	2 P, 3 W	100 A, 480 V ac
SCM3100P3W	2 P, 3 W	100 A, 250 V dc
SCM4100P12W	3 P, 4 W	100 A, 125/250 V ac
SCM4100P9W	3 P, 4 W	100 A, 3 phase 250 V ac
SCM4100P7W	3 P, 4 W	100 A, 3 phase 480 V ac
SCM4100P5W	3 P, 4 W	100 A, 3 phase 600 V ac
SCM5100P9W	4 P, 5 W	100 A, 3 phase 120/208 V ac
SCM5100P7W	4 P, 5 W	100 A, 3 phase 277/480 V ac
SCM5100P5W	4 P, 5 W	100 A, 3 phase 347/600 V ac

Issued by:
THOMAS SCIOTTO, Engineering Group Leader
Underwriters Laboratories Inc.

Reviewed by:
JON SCHUETTE, Manager CAS III
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number **20080403-E238170D**
Report Reference **E238170, 1999 December 9**
Issue Date **2008 April 3**

Page 3 of 3



**Underwriters
Laboratories Inc.®**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Ratings:

Series I
Cord Connector
Cat. No.

Type	Rating	
SCM3125C6W	2 P, 3 W	125 A, 200-250 V ac
SCM4125C6W	3 P, 4 W	125 A, 380-415 V ac
SCM5125C6W	4 P, 5 W	125 A, 200/346 V ac
		125 A, 240/415 V ac

Series II
Cord Connector
Cat. No.

Type	Rating	
SCM3100C4W	2 P, 3 W	100 A, 125 V ac
SCM3100C6W	2 P, 3 W	100 A, 250 V ac
SCM3100C7W	2 P, 3 W	100 A, 480 V ac
SCM3100C3W	2 P, 3 W	100 A, 250 V dc
SCM4100C12W	3 P, 4 W	100 A, 125/250 V ac
SCM4100C9W	3 P, 4 W	100 A, 3 phase 250 V ac
SCM4100C7W	3 P, 4 W	100 A, 3 phase 480 V ac
SCM4100C5W	3 P, 4 W	100 A, 3 phase 600 V ac
SCM5100C9W	4 P, 5 W	100 A, 3 phase 120/208 V ac
SCM5100C7W	4 P, 5 W	100 A, 3 phase 277/480 V ac
SCM5100C5W	4 P, 5 W	100 A, 3 phase 347/600 V ac

Issued by:
THOMAS SCIOTTO, Engineering Group Leader
Underwriters Laboratories Inc.

Reviewed by:
JON SCHUETTE, Manager CAS III
Underwriters Laboratories Inc.