

# Certificate of Compliance

Certificate Number **20080403-E238170H**  
Report Reference **E238170, 1999 December 15**  
Issue Date **2008 April 3**

Page 1 of 2



*Issued to:* **SCAME PARRE S.P.A**  
VIA COSTA ERTA 15  
24020 PARRE BG ITALY


*This is to certify that representative samples of* **ATTACHMENT PLUGS, PIN AND SLEEVE TYPE**  
See Addendum for Models.

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* IEC 60309-1 - Standard for Plugs, Socket-Outlets and Couplers for Industrial Purposes, Series I & II  
IEC 60309-2 - Standard for Dimensional Interchangeability Requirements for Pin and Contact-Tube Accessories

*Additional Information:* See Addendum for Ratings.

**Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.**

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

**Look for the UL Classification Mark on the product**

Issued by:  
**THOMAS SCIOTTO, Engineering Group Leader**  
Underwriters Laboratories Inc.

Reviewed by:  
**JON SCHUETTE, Manager CAS III**  
Underwriters Laboratories Inc.

# Certificate of Compliance

Certificate Number **20080403-E238170H**  
Report Reference **E238170, 1999 December 15**  
Issue Date **2008 April 3**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

#### Models:

Receptacles, Pin and Sleeve Type, Cat. Nos. SCM3100R4W, SCM3100R6W, SCM3100R7W, SCM3100R3W, SCM4100R12W, SCM4100R9W, SCM4100R7W, SCM4100R5W, SCM5100R9W, SCM5100R7W, SCM5100R5W, SCM3125R6W, SCM4125R6W, SCM5125R6W with or without defined suffixes.

#### Ratings:

##### Series I

##### Receptacle

Cat. No.	Type	Rating
SCM3125R6W	2 P, 3 W	125 A, 200-250 V ac
SCM4125R6W	3 P, 4 W	125 A, 380-415 V ac
SCM5125R6W	4 P, 5 W	125 A, 200/346 V ac 125 A, 240/415 V ac

##### Series II

##### Receptacle

Cat. No.	Type	Rating
SCM3100R4W	2 P, 3 W	100 A, 125 V ac
SCM3100R6W	2 P, 3 W	100 A, 250 V ac
SCM3100R7W	2 P, 3 W	100 A, 480 V ac
SCM3100R3W	2 P, 3 W	100 A, 250 V dc
SCM4100R12W	3 P, 4 W	100 A, 125/250 V ac
SCM4100R9W	3 P, 4 W	100 A, 3 phase 250 V ac
SCM4100R7W	3 P, 4 W	100 A, 3 phase 480 V ac
SCM4100R5W	3 P, 4 W	100 A, 3 phase 600 V ac
SCM5100R9W	4 P, 5 W	100 A, 3 phase 120/208 V ac
SCM5100R7W	4 P, 5 W	100 A, 3 phase 277/480 V ac
SCM5100R5W	4 P, 5 W	100 A, 3 phase 347/600 V ac

Issued by:  
**THOMAS SCIOTTO, Engineering Group Leader**  
Underwriters Laboratories Inc.

Reviewed by:  
**JON SCHUETTE, Manager CAS III**  
Underwriters Laboratories Inc.